



STEVE TSHWETE

LOCAL MUNICIPALITY

Your ref.

Telephone (013) 249 7000

Fax (013) 243 2550

Our ref. N Chauke

P.O. Box 14

MIDDELBURG, MPUMALANGA

2009-10-01

1050

e-mail : nchauke@stevetshwetelm.gov.za www.stevetshwetelm.gov.za

REQUEST FOR QUOTATION FOR EMERGENCY PUBLIC ADDRESS SYSTEM.

Steve Tshwete Local Municipality will utilize the PA system for announcements in its main building as well as the other separate buildings located next to the Civic Centre corner Kerk and Wanderers Avenue.

The buildings are namely Gerald Sekoto Library, 24 Hour Centre which house the Licensing and Traffic departments together with the Call Centre and the Testing station.

The Central Control Equipment shall be capable and be compliant with the Emergency Evacuation

Specification as directed by SANS 7240 documentation.

- The loudspeakers shall be compliant with the same.
- Certificates confirming proof of such compliancy shall be provided with the quotation.
- The Ceiling speakers shall be rated at 6W RMS continues use. (100 Hours)
- The Ceiling speakers shall be circular with metal grids.
- The system cabling shall be installed in such a way that upgrading thereof to full SANS Evacuation specification is possible
- The system shall service a total of 6 zones of which 3 are remote.
- Zone 1 = Second floor, Zone = First floor, Zone 3 = Ground floor of the Civic Centre; Zone 4,5 = Gerald Sekoto Library and Zone 6 = 24 Hour Centre and testing station.
- The system cabling shall be capable of carrying the loads for each zone by being of the correct inner diameter.
- The system shall allow remote control equipment to be added.
- The system shall be capable of producing 10dB more than the ambient sound level at any measured point of the installation.

Item	Bill of Materials	Qty
1	System Controller	1
2	System Amplifiers as required and as per your own specification total	
3	6 Zone Paging Microphone	1
4	19" Rack as required for all control equipment and amplifiers	1
5	Paging Microphone	1
6	Remote Amplifier (30W) with built-in 100v Audio in capability	138
7	Ceiling Speakers with fire domes - wattage as per your own specification	2
8	Sound Projectors 10Watts Indoor	2
9	Sound Projectors 20Watts Outdoor	400
10	100v Speaker cable distance - zone 1	340
11	100v Speaker cable distance - zone 2	320
12	100v Speaker cable distance - zone 3	400
13	100v Speaker cable distance - zone 4	240
14	100v Speaker cable distance - zone 5	85
15	100v Speaker cable distance - zone 6	100
16	Trunking & other	
17	Installation	
18	Training	
19	Documentation of the system to be implemented	
20	Draft Service Level Agreement	

GENERAL NOTES:

1. The Council is not bound to accept the lowest or any quotation.
2. The price must be valid for a fixed period of 60 days.
3. Quotations must be accompanied by a valid **tax clearance certificate** and the **Company Registration**.
4. Written quotations should be submitted to the office of the Senior Manager: IT Services, Room B318, Second Floor, Civic Centre, Wanderers Avenue, Middelburg, Mpumalanga or faxed to 013 243 2550 not later than 12:00 on the **12th of October 2009**.
5. Service provider not registered with council must log on to www.stevetshwetelm.gov.za or visit Mr Jabu Mahlangu at the Municipal Stores at Corner Protea and Kerk Street, Middelburg, to get the forms and submit a completed enlistment application before submitting the quotation.

For any queries, please contact **Noah Chauke**, telephone **013 249 7165/082 442 6939**.