

**STEVE TSHWETE TOWN COUNCIL**

**CHEMICAL ANALYSIS : TRIHALOMETHANES**

*Date Received : 13 September 2011*

<b>Analysis Results - µg/l [ppb]</b>	<b>Loskop Raw</b>	<b>Loskop Final</b>
<b>Bromoform</b>	<5	<5
<b>Chloroform</b>	<5	9
<b>Bromodichloromethane</b>	<10	<10
<b>Dibromochloromethane</b>	<2	<2
<b>Trichloroethylene (TCE)</b>	<5	<5

ppb - parts per billion

<b>STANDARDS 241 (2006)</b>	
<b>Class 1 ( acceptable)</b>	<b>&lt; 200 µg/l</b>
<b>Class 2 (max. allowable)</b>	<b>200 - 300 µg/l</b>

P.L.G. UYS (M.D.)